

Constancy of Performance Certificate

LGAi Technological Center S.A. (APPLUS), Notified Body No. 0370, issues this certificate to:

APPLICANT

Placed on the market under the name of

Detnov Security, S.L.

C/ De La Ciència, 30
08840 Viladecans (Barcelona) Spain

Produced in the manufacturing plant

C/ De La Ciència, 30
08840 Viladecans (Barcelona) Spain

PRODUCT

Fire detection and fire alarm system

- Fire alarm devices. Sounders
- Short-circuit isolators
- Fire alarm devices. Visual alarm devices

Models: MAD-565-I & MAD-565-I-W (Addressable sounders with flash and short-circuit isolator)

APPLICABLE REGULATION

Construction Product Regulation (CPR)

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards:

EN 54-3:2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006; EN 54-17:2005,
EN 54-17:2005/AC:2007; EN 54-23:2010

Under **system 1** for the performance set out in this certificate are applied and the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

The manufacturer, after the completion of the conformity assessment procedures and the declaration of performance, may affix the CE Marking under his responsibility

Page 1 of 4

No. 0370-CPR-6087

Date issued: 19/09/2025

First issue date: 22/10/2021

Follow-up date: before 30/09/2026

The validity of this certificate remains in effect as long as the harmonised standard, the construction product, the AVCP methods, and the manufacturing conditions at the plant are not significantly modified, unless the certificate is suspended or withdrawn by the notified product certification body.

This document is not valid without its technical annex, whose number coincides with that of the certificate.



Xavier Ruiz Peña
Managing Director
Conformity Assessment

Applus⁺

certification

LGAi Technological Center S.A. (APPLUS)
Notified Body No. 0370
Campus UAB. Ronda de la Font del Carme s/n
08193 Bellaterra, Barcelona (Spain)



Check the status
of this certificate

Certificate

Technical Annex

Annex according to EN 54-3:2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006

Fire detection and fire alarm systems. Part 3: Fire alarm devices. Sounders.

Essential characteristics	Clauses in this european standard	Mandated level(s) or class(es)
Sound level	4.2.	Pass
Frequency and sound pattern	4.3.	Pass
Durability	4.4.	Pass
Construction	4.5.	Pass Type B
Marking and data	4.6.	Pass
Reproducibility	5.2.	Pass
Operational performance	5.3.	Pass
Durability	5.4.	Pass
Dry heat (operational)	5.5.	Pass
Dry heat (endurance)	5.6.	Pass
Cold (operational)	5.7.	Pass
Damp heat, cyclic (operational)	5.8.	Pass
Damp heat, steady state (endurance)	5.9.	Pass
Damp heat, cyclic (endurance)	5.10.	Pass
Sulfur dioxide (SO2) corrosion (endurance)	5.11.	Pass
Shock (operational)	5.12.	Pass
Impact (operational)	5.13.	Pass
Vibration, sinusoidal (operational)	5.14.	Pass
Vibration, sinusoidal (endurance)	5.15.	Pass
Electromagnetic compatibility (EMC), immunity (operational)	5.16.	Pass
Enclosure protection	5.17.	Pass Type B
Attention drawing signal and message broadcast sequences	C.3.1.	NA
Synchronisation (option with requirements)	C.3.2.	NA
General testing	C.4.	NA
Broadcast message performance	C.5.1.	NA
Attention drawing signal/silence/message sequence timing	C.5.2.	NA
Message synchronization testing (option with requirements)	C.5.3.	NA

PASS; NPD = No Performance Determined, NA = Not Apply

Annex according to EN 54-17:2005, EN 54-17:2005/AC:2007

Fire detection and fire alarm system. Part 17: Short-circuit isolators

Essential characteristics	Clauses in this European standard	Mandated level(s) or class(es)
Compliance	4.1	Pass
Integral status indication	4.2	NA
Connection of ancillary devices	4.3	NA
Monitoring of detachable short-circuit isolators	4.4	NA
Manufacturer's adjustments	4.5	Pass
On-site adjustments	4.6	NA
Marking	4.7	Pass
Data	4.8	Pass
Additional requirements for software controlled short-circuit isolators	4.9	Pass
Reproducibility	5.2	Pass
Variation in supply voltage	5.3	Pass
Dry heat (operational)	5.4	Pass
Cold (operational)	5.5	Pass
Damp heat, cyclic (operational)	5.6	Pass
Damp heat, steady state (endurance)	5.7	Pass
Sulphur dioxide (SO ₂) corrosion (endurance)	5.8	Pass
Shock (operational)	5.9	Pass
Impact (operational)	5.10	Pass
Vibration, sinusoidal (operational)	5.11	Pass
Vibration, sinusoidal (endurance))	5.12	Pass
Electromagnetic Compatibility (EMC), Immunity tests (operational)	5.13	Pass

PASS; NPD = No Performance Determined, NA = Not Apply

Annex according to EN 54-23:2010

Fire detection and fire alarm system. Part 23: Fire alarm devices. Visual alarm devices

Essential characteristics	Clauses in this European standard	Mandated level(s) or class(es)
Duration of operation	4.2.1	Pass
Provision for external conductors	4.2.2	Pass
Flammability of materials	4.2.3	Pass
Enclosure protection	4.2.4	Pass Type B
Access	4.2.5	Pass
Manufacturer's adjustments	4.2.6	Pass
On site adjustments of behaviour	4.2.7	Pass
Requirements for software controlled devices	4.2.8	NA
Coverage volume	4.3.1	Pass
Variation of light output	4.3.2	Pass
Minimum and maximum effective luminous intensity	4.3.3	Pass
Light colour	4.3.4	Pass White
Light temporal pattern and frequency of lashing	4.3.5	Pass
Marking & Data	4.3.6	Pass
Synchronization (option with requirements)	4.3.7	Pass
Dry heat (operational)	4.4.1.1	Pass
Dry heat (endurance)	4.4.1.2	Pass
Cold (operational)	4.4.1.3	Pass
Damp heat, cyclic (operational)	4.4.2.1	Pass
Damp heat, steady state (endurance)	4.4.2.2	Pass
Damp heat, cyclic (endurance)	4.4.2.3	Pass
Shock (operational)	4.4.3.1	Pass
Impact (operational)	4.4.3.2	Pass
Vibration (operational)	4.4.3.3	Pass
Vibration (endurance)	4.4.3.4	Pass
SO ₂ corrosion (endurance)	4.4.4.	Pass
Electromagnetic compatibility (EMC)	4.4.5	Pass

PASS; NPD = No Performance Determined, NA = Not Apply

"Warble" tone: 800 Hz for 500 ms, then 1000 Hz for 500 ms

Continuous tone (standard): 970 Hz

Tone 800-970 Hz for 1s

High-level setting: W-4-9; 0,5 Hz / 1 Hz; Low-level setting: W-3-7; 0,5 Hz / 1 Hz